



eurofins

Attestation

On 18 July 2012 Eurofins Product Testing A/S received a sample of an adhesive with the name

Surface Bonder Xi
from
Integra Adhesives Inc

The applied method complies with the method "Standard method for the testing and evaluation of volatile organic chemical emissions from indoor sources using environmental chambers (version 1.1)" as defined by the California Department of Public Health (CDPH) - Version of February 2010.

See test report G16794.

Evaluation of the test result according to CDPH Section 01350:

- No carcinogens and reproductive/developmental toxins could be detected.
- No individual compound exceeds one-half of the lowest concentration of interest in a building (chronic REL).

The tested product complies with the requirements of the "Standard method for the testing and evaluation of volatile organic chemical emissions from indoor sources using environmental chambers (version 1.1)" as defined by the California Department of Public Health (CDPH) - Version of February 2010.

13 September 2012

Thomas Neuhaus
Head of product emission test centre

Eurofins Product Testing A/S
Smedskovvej 38
DK-8464 Galten / Denmark

Tel +45 70 22 42 76
Fax +45 70 22 42 75